

GRIMSBY POWER INC.

231 Roberts Road, Grimsby, Ontario L3M 5N2
Phone: (905) 945-5437 Fax: (905) 945-9933

Electrical Planning Requirements 5.14

It is essential that the following information be provided to:

- enable an assessment to be made on the impact of the proposed project on our Electrical Distribution System.
- enable Grimsby Power Inc.'s Engineering Department to prepare pertinent information for the developer.

Please supply answers to the following questions as soon as possible as Site Planning approval cannot be authorized until this information has been reviewed by our staff.

Preliminary electrical site plan drawings are to be submitted when this form is returned to Grimsby Power Inc. Electrical drawings are to be submitted to Grimsby Power Inc. for approval prior to any related job tenders or the commencement of any electrical construction. The drawings shall be drawn to a scale usable by Grimsby Power Inc., shall show local pole locations, proposed transformer location, proposed electrical room/metering location and show how access to the metering would be gained (i.e.: the path to the metering).

As-Built electrical site plan drawings are to be submitted to Grimsby Power Inc. after completion of the project in an Autocad™ DWG format.

Project Location: 13 Mountain and 19-23 Elm Street
Name of Project: 13 Mountain and 19-23 Elm Street
Name of Applicant: Mulvey & Banani International Inc. (Elec. Consultant)
Contact Name: Eric Cornish
Address of Contact: 90 Sheppard Ave. East, Suite 500
Toronto Ont.
M2N 3A1
Telephone: (647) 549-2506 **Fax:** ()

Service Classification (☒ as many as apply):

- ☐ Low Density Residential
- ☐ Freehold Townhouses
- ☐ Townhouse Corporation
- ☒ Apartments
- ☐ Non-Residential

Capacity of Main Service (in Amperes):

Maximum rated capacity: 2000A @ 600V

What service voltage is required (☒ one only):

- ☐ 120/240 Volt Single Phase
- ☐ 120/208 Volt Three Phase
- ☐ 347/600 Volt Three Phase

Metering Type (☒ one only):

- ☐ Bulk metering (Non-Residential Only)
- ☒ Individual metering

Number of sub-services


100A or less: ~125

101A to 200A: _____

more than 200A: _____

Service Entrance Switchboard with Utility CT and PT Compartment ☒ Yes ☐ No

Comments: _____

Signed: 
(Representative of Applicant)

Name: Eric Cornish
(Please Print)

Date: April 1, 2025

Title: Executive Vice President